

SAFETY, STRUCTURES AND FIRE DEPARTMENT

Reaction to Fire

REACTION TO FIRE CLASSIFICATION REPORT No. RA16-0153 ACCORDING TO THE EUROPEAN STANDARD NF EN 13501-1+A1:2013

Notification by the French Government to the European Commission under no. 0679
Seule la version française fait foi
The French version is legally acceptable

Product standard

NF EN 15102+A1:2011 "Decorative wallcoverings - Roll and panel form products"

Owner: TARKETT GDL S.A.

2 Op der Sang 9779 LENTZWEILER LUXEMBOURG

Commercial brand(s): PROTECTWALL 1.5 Bs2

Manufacturing unit(s): The manufacturing unit appears in the associated tests report

Brief description: Decorative wallcovering

(see detailed description in paragraph 2)

Date of issue: July 07th, 2016

This classification report certifies only the characteristics of the object submitted for testing but does not prejudge the characteristics of similar products. So it does not constitute a product certification in the sense of Articles L 115-27 to L 115-33 and R 115-1 to R 115-3 of the Consumer Code.

If this report is being issued by e-mail and/or on an electronic medium, only the hard copy of the report signed by CSTB shall prevail in the event of a dispute.

The reproduction of this classification report is only authorised in its integral form.

It comprises 4 pages.



1. Introduction

This classification report defines the classification assigned to the above-mentioned product(s) in accordance with the procedures given in the NF EN 13501-1+A1:2013 standard.

2. Product description

Decorative wallcovering tested glued (acrylic glue applied at the rate of 250 g/m 2) on A2-s1,d0 class paper-faced gypsum plasterboard substrate.

Fire-retarded heterogeneous vinyl covering constituted as follows:

- A finishing layer made of polyurethane.
- A transparent overlay made of polyvinyl chloride with a nominal thickness of 0.35 mm.
- A decorative film made of polyvinyl chloride.
- A calendered underlay made of fire-retarded polyvinyl chloride, pigments and mineral fillers, with a nominal thickness of 1.15 mm.

Overall nominal weight per unit area: 2400 g/m².

Overall nominal thickness: 1.5 mm.

Colour: beige.



3. Tests reports and tests results in support of this classification

3.1 Tests reports

Name of laboratory	Name of sponsor	Test identification	Test report No.	Test method
CSTB	TARKETT GDL S.A. 2 Op der Sang 9779 LENTZWEILER LUXEMBOURG	ES541160306	RA16-0153	NF EN ISO 11925-2:2013 NF EN 13823+A1:2015

3.2 Tests results

Test method	Product	Number of tests	Parameters	Results Compliance parameters
NF EN ISO 11925-2 30s surface exposure	PROTECTWALL 1.5 Bs2	6	Fs > 150 mm Filter paper	Not reached Not ignited
NF EN ISO 11925-2 30s edge exposure	PROTECTWALL 1.5 Bs2	6	Fs > 150 mm Filter paper	Not reached Not ignited

	Product	Number of tests	Parameters	Results	
Test method				Continuous parameters Mean values	Compliance parameters
NF EN 13823+A1	PROTECTWALL 1.5 Bs2	3	FIGRA _{0.2MJ} (W/s) FIGRA _{0.4MJ} (W/s) LFS THR _{600s} (MJ)	83.2 79.0 - 3.8	- - Not reached -
			SMOGRA(m²/s²) TSP _{600s} (m²)	68.9 148.4	
			Flaming droplets or debris	-	None

⁽⁻⁾ means: not applicable



4. Classification and direct field of application

4.1 Reference of the classification

This classification has been carried out in accordance with clauses 11.6, 11.9.3 and 11.10.1 of the NF EN 13501-1+A1:2013 standard.

4.2 Classification

Fire behaviour		Smoke production		Flaming droplets or debris
В	-	s2	,	d0

Classification: B - s2, d0

4.3 Field of application

This classification is valid for the following product parameters:

- The product described in paragraph 2.
- An overall nominal thickness of 1.5 mm.
- An overall nominal weight per unit area of 2400 g/m².
- A beige colour.

This classification is valid for the following end use conditions:

The product glued (acrylic glue applied at the rate of 250 g/m²) on any A1 or A2-s1,d0 class substrate with a density \geq 525 kg/m³ and a thickness \geq 12 mm.

5. Limitations

The present document does not represent type approval or certification of the product.

Champs-sur-Marne, July 07th, 2016

The Technician Responsible for the test

Franck GOGUEL

The Head of Reaction to Fire Unit

Gildas CREACH

.....END OF THE CLASSIFICATION REPORT